

---

SUBJECT: SAFETY

ADOPTED DATE: MAY 4, 1992

PAGE 10 OF 23

---

### EXTINGUISHER MOUNTING AND PROPER CLASSIFICATION

All extinguishers are to be mounted with a maximum travel distance to extinguisher of 75 feet and preferably next to an exit or definitely in a path of travel.

Over 40 pounds - not over 42" from top of extinguisher to floor.

Under 40 pounds - not over 60" from top of extinguisher to floor.

Extinguisher classification: "A", "B", or "C", or combination of, must be on all CO<sub>2</sub> or dry chemical extinguishers; or be designated as a "HALON" type extinguisher.

Class "A" Fires - paper, wood, rags, etc -- Fight with a water base or dry chemical type extinguisher.

Class "B" Fires - gasoline, oil, etc. -- Fight with CO<sub>2</sub> or dry chemical type extinguisher.

Class "C" Fires - electrical equipment -- Fight with CO<sub>2</sub> or dry chemical type extinguisher; or one designated as a "HALON" type extinguisher.

"HALON" - electrical or computer equipment fires -- Fight with "HALON" type extinguisher.